



Evaluation Listing CCMC 13418-L AS-18-HS

Evaluation Issued:	2008-11-20
Re-evaluated:	2013-03-05
Revised:	2013-11-08

Preface: Masterformat 06 05 23.07, Metal Truss Connector Plates

Preface Issued:	2013-03-05
------------------------	------------

Scope

These Evaluation Listings apply to light metal plate connectors used in structural lumber assemblies. The proponent has demonstrated that the product meets the requirements of the following standard:

- CAN/CSA-O86-09 Consolidation, “Engineering Design in Wood.”

The design values for the metal truss connector plates are based on test results obtained in accordance with CAN/CSA-S347-99 (R2009), “Method of Test for Evaluation of Truss Plates Used in Lumber Joints.”

Standards

CAN/CSA-S347 requires the following tests:

1. lateral resistance of teeth;
2. tensile strength of plate;
3. shear strength of plate; and
4. ultimate tensile strength of plate material.

Clause 10.8 of CAN/CSA-O86-09 does not apply to truss plates in corrosive conditions, or the use of galvanized truss plates in lumber that has been treated with a fire retardant and that is used in wet service conditions or in locations prone to condensation.

Truss plates must be manufactured from galvanized sheet steel, which should conform to G90 coating class, meeting Clause 14.4.1.2 of CAN/CSA-O86-09.

National Building Code of Canada 2010 (NBC)

NBC References

The CAN/CSA-O86-09 standard is referenced in the NBC 2010, Division B, Table 4.1.8.9. and Sentence 4.3.1.1.(1).

The CAN/CSA-S347-99 (R2009) standard is not directly referenced in the NBC 2010, however it is referenced in Clauses 10.8.1.9, 10.8.3.2.1, and 10.8.4.2. of CAN/CSA-O86-09.

Evaluation Listing CCMC 13418-L: AS-18-HS

Evaluation Issued: 2008-11-20
Re-evaluated: 2013-03-05
Revised: 2013-11-08

1. Evaluation

The product conforms to CSA S347-99, “Method of Test for Evaluation of Truss Plates Used in Lumber Joints,” and to CAN/CSA-O86-01 Consolidation (R2006). CSA S347-99 test results are as follows:

Ultimate Tensile Strength of Plate

Grade of Steel	Specified Tensile Strength Steel	Plate Thickness (mm)	Average Tested Tensile Strength (MPa)	Correction Factor
HSLA I410	482.6	1.23	482.3	1.0

Lateral Resistance of Teeth

Direction of Load	Limit States Design	
	Ultimate Lateral Resistance, n_u	Lateral Slip Resistance, n_s
Units	MPa/Plate	MPa/Plate
Type of press	Hydraulic	Hydraulic
Species of wood	S-P-F	S-P-F
Load parallel to grain, plate length parallel to load	2.93	2.72
Load parallel to grain, plate length perpendicular to load	2.22	2.45
Load perpendicular to grain, plate length parallel to load	1.51	1.79
Load perpendicular to grain, plate length perpendicular to load	1.73	1.46

Tensile Strength of Plate

Direction of Load	Limit States Design
	Tensile Resistance, t_p
Units	N/mm/Plate
Plate length parallel to load	369
Plate length perpendicular to load	297

Shear Strength of Plate

Angle (Degree)	Limit States Design Shear Resistance, v_p (N/mm/Plate)	Failure Mode	
		Shear Failure in T or C	Slots in Plate Axis
0	196	S	⊥
30	168	C	⊥
30	222	T	
60	233	C	⊥
60	256	T	
90	195	S	
120	186	T	⊥
120	157	C	
150	229	T	⊥
150	176	C	

Refer:

⊥: Slots perpendicular to plate length

C: Compression

T: Tension

S: Shear

||: Slots parallel to plate length

2. Description

The product is a galvanized G90, Grade HSLA I410, steel truss connector plate that is 1.23 mm thick and stamped with 0.0124 teeth per square millimetre. The teeth are 9.19 mm long and spaced 6.35 mm on centre (o.c.) along the width of the plate and 25.4 mm o.c. along its length. The slots in adjacent rows are staggered 3.18 mm.

3. Standard and Regulatory Information

See the [Preface](#) and the standard for explanation.

Listing Holder

Simpson Strong-Tie Canada, Limited
11476 Kingston Street
Maple Ridge, BC V2X 0Y5

Telephone: 604-465-0296

Fax: 604-465-0297

Plant(s)

Edenton, NC, U.S.A.

Disclaimer

This Listing is issued by the Canadian Construction Materials Centre, a program of NRC Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to http://www.nrc-cnrc.gc.ca/eng/solutions/advisory/ccmc_index.html, or contact the Canadian Construction Materials Centre, NRC Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

Date modified:

2014-07-16